



March 27, 2017

Mr. Joseph Newsham
Director of Facilities
Black Horse Pike Regional Board of Education
250 Schubert Ave
Runnemede, NJ 08078

RE: Lead in Drinking Water Results
Highland HS
Timber Creek HS
Triton HS
Project No. 16-3259

Dear Mr. Newsham:

Epic Environmental Services recently performed State mandated testing for lead from drinking water outlets throughout the District. Drinking water outlets included water coolers (chilled water), water fountains (non-chilled), kitchen sinks, faculty lounges, nurse's offices, life skills rooms, and any other location designated for drinking water purposes. Each location is detailed in the Sampling Plan.

The New Jersey action level for lead is 15.5 parts per billion (ppb). No lead was detected above the action level from any of the sample locations. At this time, no further action is required.

Please feel free to call me at 856-205-1077 should you have any questions.

Regards,

A handwritten signature in blue ink that reads "James J. Eberts".

James Eberts
President