



MEMO

Date: September 28, 2020
To: Anthony Tarsatana
From: Jim Eberts
Re: Mold Inspection Follow-up - Triton High School

Comments:

Mr. Tarsatana,

Epic Environmental Services performed an Indoor Air Quality inspection for the following rooms on September 10, 2020:

Room E21, Room H7, Room S7, Room C9, Room B14, Room A23

Mold was observed in the following areas:

Room H7

Table Legs

Room S7

wooden desks/prep room door

Room C9

wooden door

Room B14

books/binders

School staff was instructed to clean the affected areas.

Epic re-inspected the clean-up areas on September 24, 2020.

All areas were successfully cleaned.

Please contact me at 856-205-1077 with any questions.

James Eberts
Epic Environmental Services, LLC